

## System Component Weights

---

Use this appendix to determine the weight of your system if your floor loading requirements are critical. Table A-1 provides maximum system weights for estimating floor loading requirements.

*Table A-1 Maximum System Weights*

Configuration	Weight	Floor Loading	Area
Nonredundant	85–100 lb. (38.25–45 kg)	34.69–40.82 lb/ft <sup>2</sup> (173.86–204.55 kg/m <sup>2</sup> )	2.45 ft <sup>2</sup> (.22 m <sup>2</sup> )
Redundant	100–157 lb. (45–70.65 kg)	40.82–64.08 lb/ft <sup>2</sup> (204.55–321.14 kg/m <sup>2</sup> )	2.45 ft <sup>2</sup> (.22 m <sup>2</sup> )

Table A-2 lists weights of various VCO/4K components. This table does not include the following OEM-supplied equipment:

- Video display terminals (VDTs)
- Printers
- Modems
- DC power supplies
- EIA/TIA-232 and parallel cables
- Printer/terminal stands
- Transfer switches

Refer to the specifications supplied with this equipment for their weights and dimensions.

*Table A-2 Components and Cards*

<b>Component</b>	<b>Weight in Pounds</b>	<b>Weight in Kilograms</b>
System enclosure	26.69	12.01
Front door	10.06	4.53
Fan unit	6	2.70
AC power supply module	15.72	7.07
DC power supply module	18.34	8.25
<b>Card Type</b>		
AAC	1.20	0.57
CPA/DRC24	1.80	0.82
Combined Controller without CPU	3.84	1.73
CPU	1	0.45
Storage/Control I/O Module	2.31	1.04
D&I	1.91	0.86
ICC	2.07	0.95
16-Span I/O Module for ICC	1.12	0.51
IPRC	2.21	1.00